



LEGEND

- Factory Low voltage Wiring
- Factory Line Voltage Wiring
- - - Field Low voltage Wiring
- - - Field Line voltage Wiring
- - - Printed Circuit Trace
- - - Optional Wiring
- Optional Block Capacitor
- Circuit Breaker
- Condensate Pan
- Ground
- High Pressure Switch
- LED
- Low Pressure Switch
- Mate-N-Lock
- Multi Splice Connector
- * Optional
- OVERLOAD
- Relay contacts - N.C.
- Relay contacts - N.O.
- Relay / Contactor Coil
- Solenoid Coil
- Splice Cap
- Temperature Switch
- Thermistor
- Wire Nut

NOTES:

1. Compressor and Blower Motor thermally protected internally.
2. All wiring to the unit must comply with NEC and local codes low voltage wiring shall be Class 2 or equivalent.
3. Transformer is wired 460V (BLK/RED) lead for 460/60/3 units, 575 (GRY) leads for 575/60/3 or 380V (VIO) lead for 380/50/3. for 415/50/3 switch VIO & BRN leads at L1 & insulate VIO lead.
4. FP1 provides low temperature protection for WATER. When using ANTI-FREEZE solutions, cut JW3 jumper.
5. Typical heat pump thermostat wiring shown. Refer to thermostat IOM for wiring to the unit. T-Stat wiring must be "Class 1" and voltage rating equal to or greater than unit supply voltage.

6. 24V Alarm signal shown. For Dry Alarm contact between AL1 & AL2, cut JW1 for CXM/DXM Gen2 or JW4 DXM.
7. Transformer Secondary Ground via CXM/DXM board standoffs and screws to Control Box.

HWG3. AQUA STAT is supplied with unit and must be wired in series with the hot leg to the pump. Aqua stat is rated for voltage up to 277V.

ECM BOARD DIP SWITCH SETTINGS

| COOL CFM | | | CFM HEAT | | | EH CFM | | | ADJ CFM | | |
|----------|-----|-----|----------|-----|-----|--------|-----|-----|---------|-----|-----|
| SPD | SW1 | SW2 | SPD | SW3 | SW4 | SPD | SW5 | SW6 | SPD | SW7 | SW8 |
| 1 | ON | ON | 1 | ON | ON | 1 | ON | ON | TEST | ON | ON |
| 2 | ON | OFF | 2 | ON | OFF | 2 | ON | OFF | - | ON | OFF |
| 3 | OFF | ON | 3 | OFF | ON | 3 | OFF | ON | + | OFF | ON |
| 4 | OFF | OFF | 4 | OFF | OFF | 4 | OFF | OFF | NORM | OFF | OFF |

| DEHUM | | UNUSED | | UNUSED | | UNUSED | |
|-------|------|--------|------|--------|------|--------|------|
| SW9 | SW10 | SW11 | SW12 | SW13 | SW14 | SW15 | SW16 |
| ON | NORM | OFF | OFF | OFF | OFF | OFF | OFF |
| OFF | DH | OFF | OFF | OFF | OFF | OFF | OFF |

- AL Alarm Relay Contacts
- BM Blower Motor
- BMC Blower Motor Capacitor
- BR Blower Relay
- CAP Capacitor
- CB Circuit Breaker
- CC Compressor Contractor
- CO Condensate Overflow Sensor
- CR Compressor Relay
- CTB Common Terminal Block
- CS Current Sensor
- DHW Domestic Hot Water
- DM Damper Motor
- DTS Discharge Temperature Switch
- ES End Switch
- EWTS Entering Water Temp Sensor
- FP1 Sensor, low temp protection, water coil
- FP2 Sensor, low temp protection, air coil
- FSS Fan Speed Switch
- HP High Pressure Switch
- HPWS High Pressure Water Switch
- HR Heating Relay
- JW Jumper Wire
- LAT Leaving Air Temperature
- LOC Loss of Charge Pressure Switch
- LOR Lock Out Relay
- LWTS Leaving Water Temp Sensor
- MOD Modulating Water Valve
- MS Manual Starter
- MSC Multi Splice Connector
- MWV Motorized Water Valve
- PB Power Terminal Block
- PDB Power Distribution Block
- POT Potentiometer
- P1 Field Wiring Terminal Block
- RAS Return Air Sensor
- RVS Reversing Valve Solenoid
- SAC Start Assist Capacitor
- TB Terminal Block
- TRANS Transformer
- TS Terminal Strip
- UMT Unit Mounted Thermostat

