

- LEGEND**
- Factory Low voltage Wiring
  - Factory Line Voltage Wiring
  - Field Low voltage Wiring
  - Field Line voltage Wiring
  - Printed Circuit Trace
  - Optional Wiring
  - Optional Block Capacitor
  - Circuit Breaker
  - Condensate Pan
  - Ground
  - High Pressure Switch
  - LED
  - Low Pressure Switch
  - Mate-N-Lock
  - Multi Splice Connector
  - \* Optional
  - OVERLOAD
  - Relay contacts - N.C.
  - Relay contacts - N.O.
  - Relay / Contactor Coil
  - Solenoid Coil
  - Splice Cap
  - Temperature Switch
  - Thermistor
  - Wire Nut

- AL Alarm Relay Contacts
- BM Blower Motor
- BMC Blower Motor Capacitor
- BR Blower Relay
- CAP Capacitor
- CB Circuit Breaker
- CC Compressor Contactor
- CO Condensate Overflow Sensor
- CR Compressor Relay
- CTB Common Terminal Block
- CS Current Sensor
- DHW Domestic Hot Water
- DM Damper Motor
- DTS Discharge Temperature Switch
- ES End Switch
- EWTS Entering Water Temp Sensor
- FP1 Sensor, low temp protection, water coil
- FP2 Sensor, low temp protection, air coil
- FSS Fan Speed Switch
- HP High Pressure Switch
- HPWS High Pressure Water Switch
- HR Heating Relay
- JW Jumper Wire
- LAT Leaving Air Temperature
- LOC Loss of Charge Pressure Switch
- LOR Lock Out Relay
- LWTS Leaving Water Temp Sensor
- MOD Modulating Water Valve
- MS Manual Starter
- MSC Multi Splice Connector
- MWV Motorized Water Valve
- PB Power Terminal Block
- PDB Power Distribution Block
- POT Potentiometer
- P1 Field Wiring Terminal Block
- PR Pump Relay
- RAS Return Air Sensor
- RVS Reversing Valve Solenoid
- SAS Supply Air Sensor
- SAC Start Assist Capacitor
- TB Terminal Block
- TRANS Transformer
- TS Terminal Strip
- UMT Unit Mounted Thermostat

**NOTES:**

1. Compressor and Blower Motor thermally protected internally.
2. All wiring to the unit must comply with NEC and local codes low voltage wiring shall be Class 2 or equivalent.
3. 208/230V Transformer will be connected for 208V operation. For 230V operation, disconnect RED lead at L2 and attach ORG lead to L2. Insulate open end of RED lead. 380/420V Transformer will be connected for 380V operation. For 420V operation, disconnect VIO lead at L2 and attach BRN lead to L2. Insulate open end of VIO lead. 460V Transformer will be connected to (BLK/RED) lead. Transformer will be connected to (GRY) lead.
4. FP1 provides low temperature protection for WATER. When using ANTI-FREEZE solutions, cut JW3 jumper.
5. Typical heat pump thermostat wiring shown. Refer to thermostat IOM for wiring to the unit. T-Stat wiring must be "Class 1" and voltage rating equal to or greater than unit supply voltage.


6. 24V Alarm signal shown. For Dry Alarm contact between AL1 & AL2, cut JW1 for CXM/DXM Gen2 or JW4 DXM.
7. Transformer Secondary Ground via CXM/DXM board standoffs and screws to Control Box.

**ECM BOARD DIP SWITCH SETTINGS**

COOL			CFM			HEAT			EH			CFM			ADJ		
SPD	SW1	SW2	SPD	SW3	SW4	SPD	SW3	SW4	SPD	SW5	SW6	SPD	SW7	SW8	TEST	SW7	SW8
1	ON	ON	1	ON	ON	1	ON	ON	1	ON	ON	-	ON	ON	-	ON	OFF
2	ON	OFF	2	ON	OFF	2	ON	OFF	2	ON	OFF	+	OFF	ON	NORM	OFF	OFF
3	OFF	ON	3	OFF	ON	3	OFF	ON	3	OFF	ON						
4	OFF	OFF	4	OFF	OFF	4	OFF	OFF	4	OFF	OFF						

DEHUM		UNUSED		UNUSED		UNUSED	
SW9	SW10	SW11	SW12	SW11	SW12	SW11	SW12
ON	NORM	ON		ON			
OFF	DH	OFF		OFF			



REFER TO DATA PLATE  
POWER SUPPLY  
USE COPPER  
CONDUCTORS ONLY.

